

**Charleston County School District
 Request for Proposals
 AMENDMENT# 2
 Solicitation Number: P1904
 Description: Internal Network Cabling Services for Charleston County School District
 Date: February 20, 2019**

SUBMIT OFFER BY: March 14, 2019 BY 2:00 PM ET

QUESTIONS MUST BE RECEIVED BY: February 19, 2019 by 2:00 PM ET

NUMBER OF COPIES TO BE SUBMITTED: One (1) Original Copy, Three (3) Hard Copies and One (1) USB Flash Drive (See page 2 for details)

PROCUREMENT OFFICIAL CONTACT: Procurement Services
 Attention: Debra Cannon, CPPO, CPPB
 3999 Bridge View Drive
 North Charleston, SC 29405
 Phone: 843-566-1982
 Email: debra_cannon@charleston.k12.sc.us

The term "Offer" means your "Bid" or "Proposal".

Offers must be submitted in a sealed package. Solicitation Number & Opening Date must appear on package exterior.

You must submit a signed copy of this form with your offer. By submitting a bid or proposal, You agree to be bound by the terms of the Solicitation. You agree to hold your offer open for a minimum of ninety (90) calendar days after the Opening date.

Print Name of Offeror (Full legal name of business submitting the offer)		Date Signed
Authorized Signature (Person signing must be authorized to submit binding offer to enter contract on behalf of Offeror named above.)		Taxpayer Identification No.
Title (Business title of person signing above)		Telephone Number
Printed Name (of person signing above)		Facsimile Number
Company Address (Street, City, State & Zip Code)		
Contact Person(if different than authorized signature)		Email Address
Telephone Number	Facsimile Number	

Cover Page

Reference and acknowledge this Addendum on the offer submitted. Failure to acknowledge addendum may result in rejection of your offer.

If by virtue of this addendum you desire to change an offer already submitted, such change may be made by submitting an amended bid prior to the closing date and hour specified.

AMENDMENTS TO SOLICITATION

(a) The Solicitation may be amended at any time prior to opening. All actual and prospective Offerors should monitor the following web site for the issuance of Amendments: <http://academicdepartments.musc.edu/vpfa/finance/purchasingap/vendors/solicit-awards/bids.htm> (b) Offerors shall acknowledge receipt of any amendment to this solicitation (1) by signing and returning the amendment, (2) by identifying the amendment number and date in the space provided for this purpose on Page Two, (3) by letter, or (4) by submitting a bid that indicates in some way that the bidder received the amendment. (c) If this solicitation is amended, then all terms and conditions which are not modified remain unchanged.

This amendment was issued to address questions received.

1. At the bottom of page 5, the link to the Code of Laws Available doesn't seem to be working for me. Do you have an updated web address or could you possibly provide this documents another way?

https://www.ccsdschools.com/UserFiles/Servers/Server_2973281/File/CCSD_About_Us/CCSD_Budget_Audits/CCSD_Contract_Procurement_/CCSD_Model_Procurement_Code_20110310.pdf

2. For the Sample Elementary School

- a. Will the cabling need to be Plenum rated? **Yes.**
- b. Should we assume no firestopping will be required? **No, disturbed firestopping must be restored.**
- c. Should any NCMH2 cable managers be included? **No. If added cable count exceeds professional dress; vendor will supply the equivalent of installed cable managers at the established cost-plus rate.**

3. On page 23 under Scope of Work for Sample Elementary School 2) Miscellaneous

- a. Does "each ceiling outlet" refer to each cable or each access point location? **Each added cable.**
- b. Do the patch cables need to be Panduit brand as specified in the LAN Cabling Specs 2010 or only Made in USA with tests as outlined in Exhibit A of the RFP? **USA Panduit partner such as General 7141879, Berk-Tek 11085661, or Mohawk M58646.**

4. At the bottom of page 27 under cost for additional items as needed

- a. Could you please provide a cable length to be used for this pricing? **No. sufficient information is given for a vendor knowledgeable of governing specifications.**
- b. Should this pricing include jacks, faceplate, patch cables, labeling, testing, as-built drawings? **Yes.**
- c. Does "supporting hardware is in place" mean cabling pathways are in place? **Yes. If added cable count exceeds professional dress; vendor will supply the equivalent of installed cable managers at the established cost-plus rate.**

5. For Exhibit A

- a. Do the patch cables need to be Panduit brand as specified in the LAN Cabling Specs 2010 or only Made in USA with tests? **Quality required to support Panduit warranty.**
- b. Do the fiber jumpers need to be Panduit, Corning or only Made in USA with test results? **Quality required to support Panduit warranty.**