

Charleston County School District is testing drinking water from water taps within all schools to determine the possible presence of lead. We developed the testing program in consultation with officials from the S.C. Department of Health and Environmental Control (DHEC) and local municipal water systems.

We tested over 25 water taps at Military Magnet Academy and the results are shown below. You will find dates, locations, and results of testing in a table. You can tell what each sample represents by the sample #, for example "MM-F-100.1" refers to a fountain in the hallway across from the clinic at the Military Magnet Academy, "IM" refers to an ice machine, and "S" refers to a sink. There is a "Key" at the top of the table to explain these abbreviations.

We are pleased to report the results from this testing found that Military Magnet's drinking water was at or below the recommended level of 15 parts per billion (ppb) for "first draw" testing in all cases.

We have recently expanded a program that includes flushing of all water taps at our schools and we have expanded filtering of common-area water cooler-fountains, all of which are now filtered at Military Magnet Academy. These initiatives, in addition to the drinking water testing, demonstrate our intent to provide the highest quality of drinking water for our students.

You may also review some frequently asked questions about the testing and other helpful links about drinking water at the CCSD Facilities Management web page ([www.ccsdschools.com/watersampling](http://www.ccsdschools.com/watersampling)). If you have additional questions, you may contact our staff at (843) 566-1835 or [facilities@ccsdschools.com](mailto:facilities@ccsdschools.com).

## Military Magnet Academy

Notes: Threshold for action is 15.00 parts per billion (ppb).

Key: S=sink, F=fountain, FS=fountain sink, B=bubbler, IM=ice machine, BF=bottle filler, 1CS=one-compartment-sink, 2CS=two-compartment sink, 3CS=three-compartment sink

Sample #	Area	First-Draw Date Sampled	First-Draw Sample Result (parts per billions, ppb)	Immediate Action	Second and Flush Sample Date (if applicable)	Second First-Draw Sample Result (if applicable)	Flush Sample Result (if applicable)	Corrective Action (if applicable)
MM-S-186.1	Kitchen	5/2/20	Non Detect					
MM-S-186.2	Kitchen	5/2/20	Non Detect					
MM-S-126.1	Clinic	5/2/20	Non Detect					
MM-F-100.1	Hallway Across From Clinic	5/2/20	Non Detect					
MM-F-100.2	Hallway Across From Clinic	5/2/20	Non Detect					
MM-F-200.1	Hallway Across From Science Lab 224	5/2/20	Non Detect					
MM-F-200.1A	Hallway Across From Science Lab 224	5/2/20	Non Detect					
MM-F-200.2	Hallway Across From Science Lab 224	5/2/20	Non Detect					
MM-F-207.1	Room 207	5/2/20	Non Detect					
MM-F-200.3	Hallway Outside of Room 233	5/2/20	Non Detect					
MM-F-200.4	Hallway outside of Room 233	5/2/20	Non Detect					
MM-F-100.3	Hallway Across From ROTC Supply	5/2/20	Non Detect					
MM-F-100.4	Hallway Across From ROTC Supply	5/2/20	Non Detect					
MM-S-152.1	Culinary Arts Room	5/2/20	1.2 ppb					
MM-S-152.2	Culinary Arts Room	5/2/20	Non Detect					
MM-S-152.3	Culinary Arts Room	5/2/20	Non Detect					
MM-F-200.5	Hallway Across From Room 218	5/2/20	Non Detect					
MM-F-200.5A	Hallway Across From Room 218	5/2/20	Non Detect					
MM-S-308.1	Science Lab 308	5/2/20	Non Detect					
MM-F-300.1	Hallway Across From Media Center	5/2/20	Non Detect					
MM-F-300.2	Hallway Across From Media Center	5/2/20	Non Detect					
MM-S-312.1	Media Center Work Room	5/2/20	1.2 ppb					
MM-S-317.1	Science Lab 317	5/2/20	1.9 ppb					
MM-S-319.1	Science Lab 319	5/2/20	2.5 ppb					
MM-S-170.1	Art Room	5/2/20	Non Detect					
MM-S-170.2	Art Room	5/2/20	Non Detect					
MM-S-170.3	Art Room	5/2/20	Non Detect					
MM-F-100.5	Hallway Across From Art Room	5/2/20	Non Detect					
MM-F-100.6		5/2/20	Non Detect					